

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #5. Maintenance & Repair
Repair hole in wall and broken plastic cover in cafeteria.
Repair damage wood in window base by termites in cafeteria.
Repair baseboard damaged in cafeteria.
Repair or replace light fixtures out of order in classroom and bathroom 134, also Media center (Library)
Replace water stained ceiling tiles inside classrooms 034, 001, 107, 134, 138 and missing one in hallway in front of classroom 157.
Repair water leak coming from outside on window in classroom 165.
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #7. Heating, Ventilation, A/C Standards
Replace and repair A/C vents rusted and dirty in classrooms 034, 033, 022, 003, 107, 134, 138 and cafeteria.
CODE REFERENCE: 7. Heating, Ventilation, A/C Standards. 5(14)(b)(12) SREF. Heating/Ventilation/Air Conditioning systems shall be operational. The systems shall maintain design temperatures of at least 78° F in the summer and 68° F in the winter; and shall provide adequate humidity control. There shall be no signs of mold or mildew on carpet or walls in or around the HVAC system or toilet rooms. 5(16)(a) SREF. All occupied rooms and other rooms where odors or contaminants are generated shall be provided with ventilation.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 9/14/2020

Inspector Signature:

CM

Client Signature:

will email to client